

Appendix A

10-17-2006

City of Salisbury Water Sewer Maintenance Department Approved Product Manufacturers

- 1. Ductile Iron Pipe – Domestic, Pressure Class 350, AWWA C-151/ANSI A21.51, ANSI C-111/AWWA A21.11, AWWA C-150/ANSI A21.50:**
 - American Cast Iron Pipe Co.
 - Griffin Pipe
 - Tyler Pipe / Union Foundry
 - U S Pipe
 - Atlantic States
- 2. Ductile Iron Mechanical Joint Fittings – Domestic, Pressure Class 350, AWWA C-153/ANSI A21.53, AWWA C-111/ANSI A21.11, AWWA C-104/ANSIA A21.4:**
 - Griffin Pipe
 - Tyler Pipe / Union Foundry
 - U S Pipe
- 3. Gate Valves - Resilient Seated, NRS, (3” - 16”) 200 PSI Rating, (Open Left):**
 - American Flow Control Series 500 or 2500 (With Slotted Bolt Holes at 11:00 & 1:00 position Only)
 - Clow Series F-6100 (With Slotted Bolt Holes at 11:00 & 1:00 position Only)
 - Mueller Series 2360 (With Slotted Bolt Holes at 11:00 & 1:00 position)
- 4. Tapping Valves - Resilient Seated, NRS (4” - 16”) Flange x M.J. 200 PSI Rating, (Open Left):**
 - American Flow Control Series 500 or 2500 (No Slots on Flange side)
 - Clow F-5211 (No Slots on Flange side)
- 5. Ductile Iron Tapping Sleeve - Two-Piece (4” through 12”) M.J. 200 PSI Rating:**
 - American Flow Control Series 2800 (No Slots on Tapping Flange side)
 - Mueller H-615 (No Slots on Tapping Flange side)
- 6. Cast Iron Valve Boxes - Two-Piece:**
 - Tyler Series 6855 Slip-Type with 5 1/4” Drop Lid
- 7. Fire Hydrants - 200 PSI minimum Rating, Grease Filled, Painted Silver, 6” M.J. Shoe, (2) 2-1/2” Hose & (1) 4-1/2” Pumper Nozzles (bronze) with NST Threads, 4-1/2” Main Valve Opening (Open Left), UL Listed & FM Approved:**
 - American Flow Control MK-73-2
 - Clow Medallion
 - Mueller Super Centurion

Appendix A

10-17-2006

8. Curb Stops - Full Port Ball Valve, (Brass with Padlock Wings):

- Ford B11W & B41W
- McDonald 6101W & 6102W

9. Corporation Stops - Ball Valve, (3/4" – 1", Brass, AWWA/CC Thread Inlet x Copper Tube Compression Nut Outlet):

- Ford FB1000G
- McDonald 4701BT
- Mueller B-25008

10. Corporation Stops - Ball Valve, (1-1/2" – 2", Brass, AWWA/CC Thread Inlet x Copper Tube Pack Nut Outlet):

- Ford FB1000
- McDonald 4701B-22
- Mueller P-25008

11. Service Saddles for AC/CI/DI Pipe - (Stainless Steel Double Strap, Nylon Coated Ductile Iron Saddle):

- Romac 202N
- Smith-Blair 317

12. Service Saddles for PVC Pipe - (Brass):

- Ford S70 & S90
- McDonald 3801, 3805, 3891 & 3895
-

13. Copper Meter Setters:

- Ford CS-VBEHC72-95157-05 for 3/4" Services
- McDonald 21U207WNTT33 for 3/4" Services
- Ford CS-VBEHC74-95319-03 for 1" Services
- McDonald 21U412WNTT44 for 1" Services
- Ford VBHH77-15HBHC-41-77 for 2" Services
- McDonald 26R715WD2F7754 for 2" Services

14. Copper Tubing:

- Type "K" soft , ASTM B-88

15. Miscellaneous Brass Couplings:

- Ford
- McDonald
- Mueller

Appendix A

10-17-2006

16. Meter Boxes:

- Carson Industries #MSBCF1324-18 Box with MSCBC-1324R-OLD Lid for 3/4" Services
- Carson Industries #MSBCF1730-18 Box with MSCBC-1730R-OLD Lid for 1" & 2" Service

17. Joint Restraint:

- EBAA Megalug 1100 Series for DI/CI Pipe
- EBAA Megalug 2000PV Series for PVC Pipe
- Romac GripRing PVC/DI/CI Pipe
- UNI-FLANGE 1400 Series for DI/CI Pipe
- UNI-FLANGE 1500 Series for PVC Pipe

18. Cast Couplings, Straight & Transition:

- Ford FC1 & FC2
- Romac 501
- Smith-Blair 441

19. Repair Clamps: (repair only – not approved for new construction)

- Romac Stainless Steel SS1 & SS2
- Smith-Blair Stainless Steel 261 & 262

20. RP Backflows – University of Southern California Foundation for Cross-Connection Control & Hydraulic Research Approval:

- Ames
- Cobraco
- Febco
- Wilkins

21. Sewer Manholes – Domestic, Gray Iron Castings Conform to ASTM-A48 Class 35B, Ductile Iron Casting Conform to ASTM-A536, NCDOT 840.54 Standard, Support H20 Wheel Load, Cover dimension of 23-1/2" x 1" thick across the top with a minimum weight of 125Lbs.. Frame dimension of 7-1/2" tall x 33-1/4" across the bottom with a minimum weight of 189Lbs:

- East Jordan Iron Works V-1304
- U.S. Foundry 669KL

22. PVC Pipe & Fittings – Pressure Rated Water Distribution, ASTM D-1784, ASTM D-2241:

- 2" – SDR 13.5, Class 315
- 6" – 8" AWWA C900 – DR14, Class 200

Appendix A

10-17-2006

**23. PVC Pipe & Fittings – Gravity Sewer, ASTM D-3034, ASTM F-679, ASTM D-2665
(Charlotte Pipe, North American, or approved equal):**

- 4" – 30" SDR-35
- 4" – 6" SCH 40 NSF-DW

24. Sewer Transition Couplings – (repair only – not allowed on new construction):

- Fernco Strong Back – RC Coupling Series

25. Sewer Wyes:

- Saddle Wye – Contech PFSP & PFTP style
- Adapter – Harco 240-040 (4") & 240-060 (6")
- Wye - Lasco, Charlotte Pipe, Spears, or approved equal